

TEST CERTIFICATE

Determination of the anti-slip property of floor coverings in workrooms and fields of activities with slip danger

Tested material: **coating**

Article description: LOBADUR 2K FactoryStyle
Kind of material: mineral filler with factory-made coating structure
Material structure: 1. Substrate: mineral filler
2. Primer: 1x LOBADUR FactoryBase
(consumption: 100 g/m²)
3. Sealing: 1x LOBADUR 2K FactoryStyle
(consumption: 120 g/m²)
Colour: cement grey, cloudy
Dimensions: variable, Test samples: 1000 x 500 x 5 [mm]
Surface: unprofiled, even, fine-rough, lacquered
Producer/supplier: LOBA GmbH & Co. KG
Leonberger Str. 56-62
71254 Ditzingen

Client: LOBA GmbH & Co. KG
Leonberger Str. 56-62
71254 Ditzingen

Certificate No.: 92032001.001e

Test date: 06.11.2020

Sampling: Sent by the customer to the research institute

Test method: **DIN 51130** (edition 02/2014)
"Testing of floor coverings - Determination of the anti-slip property -
Workrooms and fields of activities with slip danger - Walking method - Ramp test"
The delivery of the test material took place in ready-to-test surface condition.

Test result: Average total acceptance angle: **7,7°**

Assessment: **Classification group of anti-slip property: R9**

SÄUREFLIESNER-VEREINIGUNG E. V.
Institut für Wand- und Bodenbeläge
Managing Director


Dipl.-Ing. Friedrich Höltkemeyer



Großburgwedel, 15.02.2021
Schu/ke

This test certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test specimen. The certificate is given for 5 years (starting from test date). Publication and reproduction of this certificate is only allowed in unabridged form.



– Institut für Wand- und Bodenbeläge –

SÄUREFLIESNER-VEREINIGUNG E.V.

Im Langen Felde 4, 30938 Burgwedel · Telefon (051 39) 99 82-0 · Telefax (051 39) 99 82-40 · E-Mail: info@saeurefliesner.de
Nach DIN EN ISO/IEC 17025 durch die DAkkS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00 aufgeführten Bereiche. Vom DIBt nach LBO unter der Kenn-Nr. NDS 20 anerkannte und nach EU-BauPVO notifizierte Stelle NB 1212.

